



Incorporating



DOP - 1

EC DECLARATION OF PERFORMANCE

Series 100 fire dampers

Series 100 HEVAC
Series 100 Plate Frame

Complying with the following EU regulation:
305/2011/EU: The Construction Products Regulation or CPR

HVC Supplies (Stourbridge) Ltd
Jason House, 91 - 95 King William Street, Amblecote, West Midlands, DY8 4EY.
United Kingdom.

BRE Global Assurance (Ireland) Ltd - 2831

The above body carried out all product sampling, testing, inspection of manufacturing plant and continuous factory production control, according to System 1 of the Construction Products Regulation and has issued the certificate of constancy of performance.
2831-CPR-P0015

Required performances to comply with BS EN 15650:2010

Fire resistance according to BS EN 1366-2 and classifications according to EN 13501-3

Table with 4 columns: SIZE, DESCRIPTION, CLASSIFICATION REF., CLASSIFICATION. It lists various fire damper configurations and their corresponding performance ratings.

Table with 2 columns: Test condition and Result. It lists nominal activation conditions, operational reliability, response delay, durability of response delay, and durability of operational reliability, all with 'Pass' results except for the last one which is 'Not relevant for Series 100 fire dampers'.

Signed for and on behalf of the manufacturer by:

Handwritten signature of Kerry Allen

Kerry Allen
Operations Director

Place of signing:
HVC Supplies (Stourbridge) Ltd, Jason House, Amblecote, West Midlands, DY8 4EY, United Kingdom

Issue G - Issued 13/01/2020